

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0328:143 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Potter Electric Signal Co, 2081 Craig Rd., St. Louis, MO 63146
Contact: *Brad Serangeli (314) 878-4321

DESIGN: Model PFC-4410 fire alarm control unit. Local, proprietary, and central station service. Automatic, manual, waterflow and sprinkler supervisory and releasing device service. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary: 120 VAC, 100 VA
Secondary: 24 VDC Nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

*Rev. 06-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager